

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106
1st Floor, 191 Racecourse Road, Flemington, Victoria 3031
P.O Box 240, North Melbourne, Victoria 3051
Phone (03) 9371 2400

TEST REPORT

Client : QEP Australia Pty Ltd
68 Prosperity Way

South Dandenong VIC 3175

Test Number : 20-002548
Issue Date : 15/06/2020
Print Date : 15/06/2020

Sample Description Clients Ref : "Kronotex Exquisit"
Laminate Flooring
Colour : Timber look
End Use : Flooring
Nominal Composition : High density fibreboard
Nominal Thickness : 8mm

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing							15/06/2020
Test Temperature (20±5degC)							22 °C
Sample Preparation	Washed with pH neutral detergent and dried						
Test Direction	Length						
Fixed/Unfixed							Unfixed
Slider No 96 Batch No							87
Length	1	2	3	4	5	SRV	
British Pendulum Number	30	30	29	30	28	29	
Classification							P2

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

205800

44332

Page 1 of 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing
- Chemical Testing : Accreditation No. 983
- Mechanical Testing : Accreditation No. 985
- Performance & Approvals Testing : Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR