

# VOC Content Test Certificate

Friday July 4<sup>th</sup>, 2008

Manufacturer: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth Victoria 3137)

Sample Description: GS100 carpet adhesive

Date Tested: September 2007

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ -13</b> <b>Green Star Office Interiors V 1.1 IEQ-11</b>	<b>GS100</b>
Carpet Adhesive 50 grams per Litre as VOC content material	<b>11 grams per Litre as VOC content per coating</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ -13</b>	<b>GS100</b>
Carpet Adhesive 50 grams per Litre as VOC content material	<b>11 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant