

VOC Content Test Certificate

Monday, 04th March 2019

Supplier: RLA Polymers Pty Ltd (215 Colchester Road, Kilsyth, VIC, 3137, Australia).

Sample Description: R2000 Universal Flooring Adhesive

Date Tested: 21 February 2019 (Tested by FORAY Laboratories – NATA Accreditation 1224)


Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

<p>Specification</p> <p>Green Building Council of Australia</p> <p>Green Star Design & As Built V1.1 13.1.1</p> <p>Green Star Interiors V1.1 12.1.1B</p>	<p>R2000 Universal Flooring Adhesive</p>
<p>General purpose adhesives and sealants: 50 grams per Litre as VOC content per material</p>	<p><1 gram per Litre as VOC content per material</p>
<p><i>We hereby certify R2000 Universal Flooring Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Nick Joy
BSc (Hons)
Consultant

CV190262