

# VOC Content Test Certificate

Tuesday, April 5, 2011

Supplier: RLA Polymers (215 Colchester Rd, Kilsyth, Victoria)

Sample Description: R555 New and Improved Formula

Date Tested: February 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1</b> <b>IEQ-11</b></p>	<p align="center"><b>R555 New and Improved</b></p>
<p>Rubber Flooring Adhesive 60 grams per Litre as VOC content material</p>	<p><b>21 grams per Litre as VOC content material</b></p>
<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b></p>	<p align="center"><b>R555 New and Improved</b></p>
<p>Rubber Flooring Adhesive 60 grams per Litre as VOC content material</p>	<p><b>21 grams per Litre as VOC content material</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

**F1102-20A**